



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8110-2135:0503
CATEGORY:	8110 - DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	Thermory USA LLC 1213 Wilmette Avenue, Suite 208, Wilmette, IL, 60091 Contact: Challinor, Mark (847) 256-8828 Email: mark@thermoryusa.com
DESIGN:	Benchmark Oak thermally modified wood decking with square edge, nominal 5/4" x 6" (1" x 5-1/8" actual) or wider. Installed on nominal 2" x 6" Douglas fir joists with a maximum of 1/4" edge-to-edge spacing. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	ASTM E84 was not conducted. The attached exterior wall covering shall be composed of noncombustible or ignition-resistant material.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, and SFM label.
APPROVAL:	Listed as exterior decking material for use in the Wildland Urban Interface areas when attached exterior wall covering is composed of noncombustible or ignition-resistant material. Refer to listee's Installation Instruction Manual for details.
NOTES:	Test Protocol SFM 12-7A-4A

9/9/2025 GA



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 09/16/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division